

Utility Pole Compliance Analysis

Needham, MA

U-Pole #	Address	Eversource Co-Location Compliance (Y/N)	Eversource Non-Compliance Reason	Town's Preferred Residential 50' Separation Compliance (Y/N)	Town's Preferred Driveway 20' Separation Compliance (Y/N)	Notes
16/15	234 Brookline Street	No	Attached 3 Way Primary Power Lines	No @ 30+' Separation	Yes	SUBJECT U-Pole U-Pole greatly needs re- positioning/replacement.
16/16	228 Brookline Street (Subject)	Yes	N/A	No @ 29+' Separation	No = 2' Separation	
16/17	216 Brookline Street	No	Attached Transformer	No @ 27+' Separation	No = 3' Separation	
16/18	204 Brookline Street	Yes	N/A	No @ 33+' Separation	Yes	
19	196 Brookline Street	No	Attached Double Primary Lines & 3 Way Primary Power Lines	Yes	No = 17' Separation	
20	184 Brookline Street	No	Attached Double Primary Lines	Yes	No = 2" Separation	
21	176 Brookline Street	No	Attached Double Primary Lines	Yes	Yes	
22	5 Bancroft Street, Brookline Street side	No	Attached Transformer	No @ 32' Separation	Yes	
23	5 Bancroft Street, Brookline Street side	No	Attached 3 Way Primary Power Lines		Yes	
2/24'	4 Bancroft Street, Brookline Street side	No	Attached Transformer	No @ 26' Separation	Yes	
	136 Brookline Street	No	Attached Battery Box	No @ 39+' Separation	No = 2' Separation	
	130 Brookline Street	No	Attached Control Box w/Stand	Yes	Yes	
	115 Brookline Street	Yes	N/A	No @ 34+' Separation	Yes	

1/5th mile from target.