

*Town of Needham, Massachusetts 02492  
Invitation for Bids  
Water Treatment Plant: Filter Drain Actuator and Valve Replacement  
Project #22DPW177C*

**Notice to All Prospective Bidders**

**ADDENDUM #\_1\_ RELEASED (January 19, 2022)**

The Town received the following requests for clarification by prospective bidders before the deadline:

- Are the four (4) valves to be replaced along with the actuators? **Yes**
- Will all electrical wiring be coordinated and directed by Needham WTP? Please confirm. **Yes, by Weston & Sampson the Town's On-call electrical contractor.**
- Will all programming and commissioning be done by others? Please confirm. **Yes, by Weston & Sampson our incumbent On Call Mechanical Controls Contractor.**
- Are the old actuators to be turned over to Needham WTP or disposed of? **No, they can be disposed of.**
- The Supplier inquired if control voltage is 24V or 120 V. **It is 120V.**

The specifications and drawings for the entire project can be found in the bid package, on our website [needhamma.gov/bids.aspx](http://needhamma.gov/bids.aspx).

The above responses were prepared by or in consultation with:

**Andrew Fagan, Administrative Analyst  
Steve Cusick, Water Treatment Plant Manager**

**The Town reserves the right to reject any and all bids as determined to be in the best interests of the Town and to waive minor informalities.**